

Er. D.NATARAJAN, B. E. (CIVIL), M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam – 631002

Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore – 632 009

Cell: 9443106470, 8056631312, 9788026626

Email: dnatarajan8@gmail.com

Ref: Collector, VLR Lr. No. ந.க.அ/6/31531/2013 Dated: 23.09.2015


STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A


- Name of the School and Door no of the Building : **WISDOM PARK INTERNATIONAL SCHOOL**
NH 46 (or) Chennai – Bangalore Road, Chengalikuppam Village,
Ambur Taluk, Vellore District – 635 807
- Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S. F. Nos. 30/1A, 2B, 5A, 5B2A, 6A, 6B, 6C, 6D, 8A, 30/3, 4, 9, 10,
& 31/3B, NH 46 (or) Chennai – Bangalore Road,
Chengalikuppam Village, Ambur Taluk,
Vellore District – 635 807
- Year of construction : **SOUTH SIDE BUILDING:**
Ground Floor: RCC: 2015; First Floor: RCC: 2018
EASTERN SIDE BUILDING:
Ground Floor: RCC: 2014; First & Second Floor: RCC: 2015
- Approximates cost of construction as per current rate : Rs. 440.00 Lakhs
- Purpose for which the building is being used or proposed to be used : Educational
- Purpose for which the building has hitherto been used : Educational
- Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Isolated Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given : Flooring: Ceramic Tiled
Roof: RCC Slab
- Period for which the license is require : May be issued from **20.12.2018 to 19.12.2021**
(For Three years only)
- Number of persons to be accommodated Refer "ANNEXURE" to this : **Eight Hundred (800) Pupils only**

Place : Vellore

Date : 20.12.2018

Signature of the Correspondent




Signature of the Engineer
Er. D. NATARAJAN, B. E. (CIVIL), M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore - 632 009.
Cell 94431 06470, 99430 09341

மரம் வளர்ப்போம்.



மழை பெறுவோம்

Er. D.NATARAJAN, B.E. (CIVIL), M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam – 631002
Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore – 632 009
Cell: 9443106470, 8056631312, 9788026626
Email: dnatarajan8@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

WISDOM PARK INTERNATIONAL SCHOOL, CHENGALIKUPPAM VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation:

- | | | |
|------|--|-------------------|
| i. | Depth below ground level | : 08ft below G.L |
| ii. | Nature of soil met out in the foundation | : Ordinary Soil |
| iii. | Pressure at foundation | : 12 tones / Sq.m |
| iv. | Probable safe bearing capacity of the foundation | : 18 tones / Sq.m |

2. Superstructure:

- | | | |
|-----|--|---|
| i. | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 30 Kg / Sq.cm.
b) Masonry : 10 tones / Sq.m. |
| ii. | Nature of masonry and concrete And its safe permissible stress | : Brick masonry in cm: 30 tones / Sq.m.
R.C.C : 40 Kg / Sq.cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 20.12.2018 to 19.12.2021.

Signature of the Correspondent




Signature of the Engineer
Er. D. NATARAJAN, B.E., (CIVIL) M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore - 632 009.
Cell 94431 06470, 99430 09341

மரம் வளர்ப்போம். மழை பெறுவோம்.

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam – 631002

Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore – 632 009

Cell: 9443106470, 8056631312, 9788026626

Email: dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

WISDOM PARK INTERNATIONAL SCHOOL, CHENGALIKUPPAM VILLAGE

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
WISDOM PARK INTERNATIONAL SCHOOL NH 46 (or) Chennai – Bangalore Road, Chengalikuppam Village, Ambur Taluk, Vellore District – 635 807	SOUTH SIDE BUILDING: GF: RCC: 03 Yrs; FF: RCC: New EASTERN SIDE BUILDING: GF: RCC: 04 Yrs; FF & SF: RCC: 03 Yrs	Rs. 440.00 Lakhs	Ground Floor + 2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 20.12.2018 to 19.12.2021	800 Pupils only	Building is structurally sound

Signature of the Correspondent



Signature of the Engineer
Er. D. NATARAJAN, B.E., (CIVIL), M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore - 632 009.
Cell 94431 06470, 99430 09341